



November 17, 2023 (10:00 a.m.)

RFP #2324-26
Sunrise Park Playground Equipment

Addendum #2

The following addendum is for the above-mentioned RFP. The due date for proposals **HAS CHANGED** as a result of this addendum. **Proposals are now due December 15, 2023 by 5:00 pm.**

Addendum:

The following is an answer to a question that arose during the pre-bid site meeting on 11/15 at 10:00 am.

1) Q: How would the City like drainage under the playground area addressed?

A: After further review of the site conditions, the City will require a minimum of two dry wells (exact location TBD) to be installed below the gravel sub-base for the playground surfacing. Dry wells shall be 2 feet in diameter, 4 feet in depth, and filled with clean, uncontaminated AASHTO #57 stone.

The above notes constitute the entirety of this Addendum,

Bethany Grissom—Park Planner
City of Norman Parks and Recreation Department
405-366-5475 (office)
405-366-5470 (fax)